

令和7年度

原水		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	最大値	最小値	平均値	基準値
採取日	単位																
時間		R7.4.7	R7.5.12	R7.6.5													
水温	℃	16.0	19.4	19.0													
水位	m	-	-	-													
電気伝導度	mS/m	130	120	110										130	110	120.0	
過マンガン酸消費量	mg/L	16	17	12										17	12	15.0	
塩化物イオン	mg/L	320	260	250										320	250	276.7	
Cd	mg/L	-	-	-													0.01
t-CN	mg/L	-	-	-													ND
Pb	mg/L	<0.005	<0.005	<0.005										0	<0.005		0.01
Cr+6	mg/L	-	-	-													0.05
As	mg/L	-	-	-													0.01
t-Hg	mg/L	-	-	-													0.001
Ar-Hg	mg/L	-	-	-													ND
PCB	mg/L	-	-	-													ND
シクロメタン	mg/L	-	-	-													0.02
四塩化炭素	mg/L	-	-	-													0.002
1,2シクロエタン	mg/L	-	-	-													0.004
1,1,1シクロエチレン	mg/L	-	-	-													1
シス1,2シクロエチレン	mg/L	-	-	-													0.04
1,1,1トリクロエタン	mg/L	-	-	-													1
1,1,2トリクロエタン	mg/L	-	-	-													0.006
トリクロエチレン	mg/L	-	-	-													0.1
テトラクロレチレン	mg/L	-	-	-													0.01
1,3シクロプロペン	mg/L	-	-	-													0.002
チウラム	mg/L	-	-	-													0.006
シマジン	mg/L	-	-	-													0.003
チオベンカルブ	mg/L	-	-	-													0.02
ベンゼン	mg/L	-	-	-													0.01
セレン	mg/L	-	-	-													0.01
アンモニア、アンモニウム化合物、亜硝酸化合物及び硝酸化合物	mg/L	-	-	-													200
フッ素	mg/L	0.2	0.1	0.1										0.2	0.1	0.1	0.8
ホウ素	mg/L	0.4	0.4	0.2										0.4	0.2	0.3	1

令和7年度

No1井戸

[illegible]

令和7年度

No3井戸

[illegible]

令和7年度
No4(濾水シート)

[illegible]

放流水

[illegible]